

Vehicle Impact (7154)

IFC: 1207.11.7, 1207.11.7.1 (New), 1207.11.7.2 (New), 1207.11.7.3 (New), 1207.11.7.3.1 (New), 1207.11.7.3.2 (New), 1207.11.7.3.3 (New), Figure 1207.11.7.1 (New), Figure 1207.11.7.3 (New)

Proponents: Larry Sherwood, on behalf of Sustainable Energy Action Committee, representing Interstate Renewable Energy Council (Larry@irecusa.org); Kevin Reinertson, Riverside County Fire Dept., representing California Fire Chiefs Association FPO (kevin.reinertson@fire.ca.gov); Benjamin Davis, CA Solar & Storage Association, representing CA Solar & Storage Association (ben@calssa.org); Joseph H. Cain, P.E., Solar Energy Industries Association (SEIA), representing SEIA (JoeCainPE@gmail.com)

2021 International Fire Code

Revise as follows:

1207.11.7 Protection from impact. ~~Stationary storage battery systems~~ ESS installed in a location subject to vehicle damage shall comply with Section 1207.11.1 or 1207.11.2 as applicable. ~~be protected by approved barriers. Appliances in garages shall also be installed in accordance with Section 304.3 of the International Mechanical Code.~~

Add new text as follows:

1207.11.7.1 Garages Where an ESS is installed in the normal driving path of vehicle travel, defined as a line perpendicular to the garage vehicle opening to the back wall, extending 3 ft. (914 mm) to either side along the back wall and to a height of 48 in. (1219 mm), (See Figure 1207.11.7.1) it shall be protected by barriers designed to resist, deflect, or visually deter vehicle impact. Barriers shall comply with Section 1207.11.3.

Exception: Where the clear height of the vehicle garage opening is 7 ft 6 in. (2286 mm) or less, ESS installed not less than 36 inches (914 mm) above finished floor are not subject to vehicle impact protection requirements.

-

1207.11.7.2 Other locations subject to vehicle impact Where an ESS is installed in a location other than as defined in 1207.11.7.1, and subject to vehicle damage, it shall be protected by approved barriers that comply with 1207.11.7.3

1207.11.7.3 Impact Protection Options Where the ESS is in the normal driving path of vehicle travel, one of the following methods shall be used. (See Figure 1207.11.7.3)

-

1207.11.7.3.1 Bollards Bollard construction shall comply with one of the following:

1. 48 in. L x 3 in. Dia. (1219 mm x 76 mm) SCH. 80 steel pipe embedded in a concrete pier 12 in. (304 mm) deep and 6 in. (152 mm) diameter, with 36 in. (914 mm) of pipe exposed, filled with concrete, and spaced at a maximum interval of 60 in. (1524 mm) Each bollard shall be located not less than 6 in. (152 mm) from an ESS.
2. 36 in. H x 3 in. (914 mm x 76 mm) Dia. SCH. 80 steel pipe fully welded to an 8 in. x 8 in. x ¼ in. (203 mm x 203 mm x 6.4 mm) thick steel plate and bolted to a concrete floor by means of (4) ½ in. (13 mm) concrete anchors with 3 in. (76 mm) minimum embedment. Spacing shall be 60 in. (1524 mm) maximum, and each bollard shall be located not less than 6 in. (152 mm) from the ESS.
3. Pre-manufactured steel pipe bollards shall be filled with concrete and anchored in accordance with the manufacturer's installation instructions, 60 in. maximum spacing. Located not less than 6 in. (152mm) from the ESS.

1207.11.7.3.2 Wheel barriers Wheel barrier construction shall comply with one of the following:

-
1. 6" H x 6" W (152 mm x 152 mm) wheel barrier made of concrete or polymer, anchored to the concrete floor every 36 in. (914 mm) minimum and located not less than 54 in. (1372 mm) from the ESS.. Minimum (2) ½ in. (13 mm) diameter concrete anchors with 3 in. (76 mm) embedment per barrier shall be used. Spacing between barriers shall be a maximum of 36 in. (914 mm).

2. Pre-manufactured wheel barriers shall be anchored in accordance with the manufacturers installation instructions.

1207.11.7.3.3 Other Methods

1. Approved method designed to resist a 2000 lb impact in the direction of travel at 24 in. above grade.




Figure 1207.11.7.3
Impact Protection Options

Reason:

Summary

First, a minor editorial change is needed to replace stationary storage battery system with ESS . This should have been part of a global change last cycle.

Second, the last sentence referring to appliances has been removed. Section 304.3 is related to the elevation of ignition sources not vehicle impact protection. The concern about raising ignition sources has historically been applied to fuel-fired appliances such as water heaters. These types of appliances are the only equipment able to be listed as flammable vapor ignition resistant. Even when a water heater has not been evaluated to ANSI Z21.10, only the actual ignition source needs to be elevated above 18", not the entire water heater. It's important to note that NFPA 70 does not consider the area below 18" a classified location in above-grade residential garages.

The third and most substantial change addresses the need for a clearly defined area in which a residential garage ESS installation would trigger the "Subject to Vehicle Damage" requirement found in 1207.11.7. The existing language has led to widely varying interpretations and enforcement of impact protection.

- **New language (1207.11.1)** has been added to define this area and set the expectation that the barriers are intended to deflect, resist, or visually deter an impact. This language mirrors the existing Section 312.3 in the IFC.
- A minimum installation height of 48" within the likely impact area has been added to allow elevation of the ESS as a permissible mitigation option. An exception to this 48" minimum has been included to recognize that a reduced garage opening height would thereby limit vehicle height and allow a lower placement of equipment before additional protection is needed. This exception is inspired by existing IMC Commentary:

"The height of the vehicle entry opening of the garage or carport can be used as a guide in determining how tall of a vehicle could be driven into the garage or carport"

- A new Figure 1207.11.7.1 has been added to illustrate the zones in which a typical residential garage ESS installation would trigger the need for impact protection. This figure is based on existing IMC commentary related to the installation of fuel-fired appliances that may pose a fire hazard when damaged. The IMC commentary Figure 304.6 (2) has been modified to reflect common ESS installation locations and takes a similar approach to mitigating the risk of impact.
- New language (1207.11.7.2) has been added to address other than garage locations that may also have vehicle access such as residential driveways, and also allows some flexibility to the AHJ and installer for larger, non-typical, or custom residential garages where the normal path of vehicle travel falls outside of the area defined in 1207.11.7.1.

Finally, the prescriptive barrier and post designs per IBC 1607.10 or IFC 312.2 may be appropriate for an energy storage system in a public access parking lot, garage, or other thoroughway. We are therefore not proposing any changes to 1207.4.5. However, the forces assumed in these sections are not representative of the impact scenarios expected in a private residential garage reserved for permanent occupants.

For example, the calculation in IBC 1607.8.3 results in approx. 12K lb-force applied to the anchorage, which causes readily available bollard to concrete connections to fail. This effectively eliminates the possibility of retrofitting a floor mounted bollard as a solution. Additionally, the posts described in IFC 312.2 can not be reasonably installed in an existing residential garage, and although uncommon especially those with tensioned concrete slabs. This leaves AHJs and installers with no guidelines for a retrofit bollard designed to deter vehicle operators from carelessly striking the ESS units. While IFC Section 312.3 does allow an alternative approach, designers, installers, and code officials will benefit from more explicit guidance within Section 1207.11. In new construction posts designed in accordance with Section 312 may be feasible, however it is unlikely that a homebuilder would be able to anticipate the installation of an ESS in a specific location in a garage. The proposed options for impact protection were inspired by existing IMC commentary figure 304.6(2). These options have been modified to provide a consistent amount of force resistance across the available choices, something the IMC commentary does not do. These options more reasonably reflect the expected impact scenario described in the commentary text:

“The barriers shown in the commentary figure will not eliminate all possibility of a motor vehicle contacting the appliances but will offer a reasonable warning to a driver who is slowly navigating near the appliances”

And:

“Although this section does not specifically require the impact protection provided to stop any type of vehicle at any speed, the intent is for the impact protection to cause the driver to want to stop vehicle movement out of concern for damage that could be occurring. The choice of the type, structural capacity and the location of barriers is the responsibility of the designer.”

Between limiting the locations that ESS Batteries can be installed, and defining the requirements when impact protection is required, the result will be an improved level of protection from the risk of vehicle impacts, and damage mitigation if incidents do occur.

Technical Justification

An engineering review of the impact protection guidance found across the I-Codes and ASCE 7-16 was completed. Specifically Section 312 of both the prior and existing IFC, Section 4.5.3 of ASCE 7-16, and commentary language and figures associated with Section 304.6 of the IMC.

It is important to recognize that the prescription of the IFC Section 312 for bollards in public driving areas does not lead to a bollard that will resist 12k lbs. as prior editions of the code suggested.. In actual testing ((Harrison (SwRI), Evaluation of collision protection provided by vehicle impact bollards and propane cylinder exchange cabinets 2013)) the static resistance was between 900 lbs. at 36” (2.7k lbs. reaction) and 11k lbs. at 36” (33k lbs. reaction).

ASCE 7-16 specifies vehicle barrier systems must resist 6k lbs. load at between 18” and 27” (9k to 13.5k lbs. reaction) There are no commonly available retrofittable bollards that can do this in an average residential garage without adding thickness to the concrete.

The IMC commentary figure when back calculated sets a bar of physical resistance which seems more appropriate to this risk and allows for solutions that are more practical to apply. For example, the bollard shown in IMC commentary Figure 304.6(2) will take an impact of about 625 lbs. load applied at 24”, resulting in a 1250 lb reaction force at the post to base plate connection. Likely outcomes based on this force include:

- No damage at 0.5 mph impact from an average passenger car.
- Bollard would deflect permanently a few inches at a 2 mph collision speed
- Anchor bolts would shear off or blowout at a 5 mph collision speed.

The limitation is mostly the concrete to base plate connection. The IRC requires a 2500-3000 psi mix for garages, and garages are often of stronger mix, especially in freeze prone areas. The average garage concrete slab will fall within these specifications: 2500 - 4000 psi concrete with 5" min thickness. Using 1/2" epoxy anchors this equates to roughly a 2mph impact that could be sustained without significant damage to the bollard. This is aligned with a standard Uline 4.5" bollard with 1/8" wall thickness and a 8x8x3/8" base plate. More strength requires a larger base plate, as the limitation is the connection to the concrete.

The bolt down bollard specified in this proposal will take a 2000 lb impact, 24" off the ground with no damage, given 3000 psi concrete. More than 6" of permanent deflection would require a very significant force, and then only touching the face of the ESS. This seems a reasonable level of protection, and clearance distance.

This proposal was prepared by the Sustainable Energy Action Committee (SEAC), a forum for all stakeholders (including, but not limited to, AHJs, designers, engineers, contractors, first responders, manufacturers, suppliers, utilities, and testing labs) to collaboratively identify and find solutions for issues that affect the installation and use of solar energy systems, energy storage systems, demand response, and energy efficiency. The purpose is to facilitate the deployment and use of affordable, clean and renewable energy in a safe, efficient, and sustainable manner.

All recommendations from SEAC are approved by diverse stakeholders through a consensus process.

Bibliography:

Harrison, O. (2013). Evaluation of Collision Protection provided by vehicle impact bollards and propane cylinder exchange cabinets (Rep. No. 18.19083.01.107.FR1). Southwest Research Institute.

Cost Impact: The code change proposal will not increase or decrease the cost of construction. This proposal clarifies and gives more technical rigor to the requirements.